



**PANVEL MUNICIPAL CORPORATION**  
**Tal. Panvel, Dist. Raigad. Pin No. 410206**



Office No- 27458040/41/42

Fire Office No- 27461500

Email-Panvelcorporation@gmail.com

Fax No- 022-27452233

Outword/No/Pmc/Fire/ 2121/Ref. No.460/ ९८५५ /

Date-२९ /०६/2024

APPENDIX - VII

**FIRE SAFETY CERTIFICATE**

Certified that the **M/S. DSP INTERNATIONAL SCHOOL** at Plot No. 23, Sector-09, Kamothe, Navi Mumbai comprised of Ground + 5th Upper Floor owned / occupied by **M/S. MAJI AAMDAR DATTUSHETH PATIL SHIKSHAN PRASARAK MANDAL's** have complied with the fire prevention and fire safety requirements in accordance with rule of State/UT Fire Service Rules, and verified by the officer concerned of Fire Service on **14/06/2024** in the presence of Principal **Mr. Vimmi Kapoor / Mr. Prakash Mhatre & M/s. S. B. Fire Safety Services, Fire License Agency** and that the building/premises is fit for occupancy up to Class XII with effect from 20/06/2024 for a period of 1 Year in accordance with rule and subject to compliance of specific conditions as appended :-

- 1) In build Fire Fighting System Should be kept in good working condition all the time.
- 2) As per the Maharashtra Fire Prevention & Life Safety Act, 2006 it is statutory requirement to check the in-built fire protection system from licensing agency twice in a year (in the month of July & December) & produce the Form 'B' certificate to this department
- 3) School management shall trained all staff members to operate the Fire Extinguisher.

Issued on 20/06/2024 at Navi Mumbai by

Signature with Seal :

Name : Pravin B. Bedkhe

Designation : Chief Fire Officer

Name & Address of Department / Office: Panvel Municipal Corporation

To,

Principal,

**M/S. DSP INTERNATIONAL SCHOOL**

**M/S. MAJI AAMDAR DATTUSHETH PATIL SHIKSHAN PRASARAK MANDAL's**

Plot No. 23, Sector-09, Kamothe, Navi Mumbai